RESTORE TRENCH OPENING WITH (2) 1-1/2" LAYERS OF BITUMINOUS CONCRETE TEMPORARY PAVEMENT



EXISTING SURFACE

4" SCH 80 PVC DUCT

CONCRETE SURROUND -

TRENCH DETAIL (BTD 4" DUCT INSTALLATION)

NOT TO SCALE

Nov 3, 2016

SS-05